



NOTES:

- 1.) PVC EXTENSIONS SHALL NOT BE USED ON VALVE BOX INSTALLATION.
- 2.) THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO COME UP TO 4 FOOT DEPTH BELOW FINISHED GRADE.
- 3.) ALL EXISTING AND PROPOSED VALVE BOXES SHALL BE ADJUSTED TO FINISHED GRADES AS ESTABLISHED IN THE FIELD.
- 4.) VALVES SHALL NOT BE PLACED IN HANDICAPPED RAMPS.
- 5.) ALL EXPOSED EDGES OF CONCRETE PAD SHALL BE CHAMFERED 1/2"

UTILITIES DEPARTMENT		GATE VALVE 12" & SMALLER	R-1
REV.	DATE		
1	MAR '12		