



NOTES:

1. REDUCE MAIN TO 4" PVC (C-900) FOR PERMANENT CUL-DE-SAC CONNECTIONS ONLY. FITTINGS AS REQUIRED.
2. 5'-0" MIN. SEPARATION BETWEEN POTABLE WATER, RECLAIMED WATER AND WASTE WATER SHALL BE MAINTAINED.
3. ABOVE GROUND PIPING TO BE PAINTED PURPLE WITH NON-POTABLE MARKINGS.
4. WHERE POSSIBLE LOCATE ON NORTHERLY AND WESTERLY SIDE OF ROAD AND ON THE OPPOSITE SIDE OF ROAD FROM THE WATER LINE.

CITY OF P.C.B.
UTILITIES DEPARTMENT

RECLAIMED WATER
LOCATION DETAIL

R-7

REV.	DATE
1	MAR '12

.....
DATE OF APPROVAL