



NOTES:

- 1.) PVC EXTENSIONS SHALL NOT BE USED ON VALVE BOX INSTALLATION.
- 2.) THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO COME UP TO 4 FOOT DEPTH BELOW FINISHED GRADE.

CITY OF P.C.B.  
UTILITIES DEPARTMENT

SEWER GATE  
VALVE AND  
BOX DETAIL

S-7

REV.	DATE
1	MAR '12

.....  
DATE OF APPROVAL