



NOTES:

- 1.) PVC EXTENSIONS SHALL NOT BE USED ON VALVE BOX INSTALLATION.
- 2.) THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO COME UP TO 4 FOOT DEPTH BELOW FINISHED GRADE.
- 3.) ALL FORCE MAINS 2" & BELOW SHALL HAVE HAND WHEEL INSTEAD OF THE OPERATING NUT.
- 4.) PRECAST "DONUT" VALVE COLLARS ARE NOT ACCEPTABLE UNLESS WRITTEN AUTHORIZATION IS PROVIDED BY THE CITY.

CITY OF P.C.B. UTILITIES DEPARTMENT		DUCTILE IRON SEWER GATE VALVE DETAIL	S-15
REV.	DATE DATE OF APPROVAL	
1	MAR '12		