



- 1.) ABOVE DETAIL IS BASED ON 2" COMBINATION AIR/VACUUM RELEASE VALVE. CHANGE PIPE AND FITTINGS ACCORDINGLY FOR OTHER VALVE SIZES AND TYPES. VALVE SIZES TO BE DETERMINED BY THE ENGINEER AND APPROVED BY THE CITY.
- 2.) THE MINIMUM DIMENSION FROM TOP OF PIPE TO FINISHED GRADE SHALL BE 4.0 FEET.

CITY OF P.C.B.  
UTILITIES DEPARTMENT

AIR AND/OR  
VACUUM RELEASE  
VALVE DETAIL

W-12

REV.	DATE
1	MAR '12

.....  
DATE OF APPROVAL