



NOTES:

- 1.) ALL PIPE AND FITTINGS 2" AND SMALLER SHALL BE THREADED SCHEDULE 40 GALVANIZED STEEL OR BRASS.
- 2.) PROVIDE PROTECTION AGAINST FREEZING, INSULATE OR "HOT BOX".
- 3.) TWO PIPE SUPPORTS REQUIRED.

CITY OF P.C.B. UTILITIES DEPARTMENT		BACK FLOW PREVENTER ASSEMBLY DETAIL	W-14
REV.	DATE	..... DATE OF APPROVAL	
1	MAR '12		