



NOTES:

- 1.) ALL PIPE AND FITTINGS 2" AND SMALLER SHALL BE THREADED SCHEDULE 40 BRASS OR PVC.
- 2.) PROVIDE PROTECTION AGAINST FREEZING, INSULATION OR "HOTBOX".

CITY OF P.C.B.
UTILITIES DEPARTMENT

REDUCED PRESSURE
BACK FLOW
PREVENTER FOR
3/4, 1, 1-1/2 & 2"

W-15

REV.	DATE
1	MAR '12
2	OCT '15

.....
DATE OF APPROVAL