



**NOTES:**

- 1.) ABOVE DETAIL IS BASED ON 2" COMBINATION AIR/VACUUM RELEASE VALVE.
- 2.) CHANGE PIPE AND FITTINGS ACCORDINGLY FOR OTHER VALVE SIZES AND TYPES. VALVE SIZES TO BE DETERMINED BY THE ENGINEER AND APPROVED BY THE COUNTY PRIOR TO INSTALLATION.
- 3.) THE MINIMUM DIMENSION FROM ELBOW INVERT TO FINISHED GRADE SHALL BE 4.0 FEET.

CITY OF P.C.B. UTILITIES DEPARTMENT		OFFSET AIR AND/OR VACUUM RELEASE VALVE DETAIL	W-13
REV.	DATE		
1	MAR '12	..... DATE OF APPROVAL	