



- NOTES:
- 1.) PVC EXTENSIONS SHALL NOT BE USED ON VALVE BOX INSTALLATION.
  - 2.) THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO COME UP TO 4 FOOT DEPTH BELOW FINISHED GRADE.
  - 3.) ALL WATER, SEWER & RECLAIM MAINS 2" & BELOW SHALL HAVE HAND WHEEL INSTEAD OF THE OPERATING NUT.
  - 4.) PRECAST "DONUT" VALVE COLLARS ARE NOT ACCEPTABLE UNLESS WRITTEN AUTHORIZATION IS PROVIDED BY THE CITY.

CITY OF P.C.B.  
UTILITIES DEPARTMENT

2" DUCTILE IRON GATE  
VALVE DETAIL (WATER,  
SEWER & RECLAIM)

M-33

REV.	DATE
1	JUL '16

.....  
DATE OF APPROVAL